

**AmeriSci New York**117 EAST 30TH ST.  
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-3114

**PLM Bulk Asbestos Report**

Spectrum Environmental Associates, Inc. **Date Received** 02/03/21 **AmeriSci Job #** 221021080  
**Attn:** Bill Massman **Date Examined** 02/04/21 **P.O. #**  
**P.O.Box** 1024 **ELAP #** 11480 **Page** 1 of 14  
**RE:** 21-131; Woodstock Library; Renovation Survey / Interior  
Schenectady, NY 12301

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
1 1	221021080-01 <b>Location:</b> Main Floor / Throughout - Floor Tile Adhesive	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Yellow, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 18.4%			
2 1	221021080-02 <b>Location:</b> West Addition / Throughout - Floor Tile Adhesive	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Yellow, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 17.4%			
3 2	221021080-03 <b>Location:</b> Main Floor / Throughout - Beige 12 x 12 Floor Tile	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Beige, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 10.1%			
4 2	221021080-04 <b>Location:</b> West Addition / Throughout - Beige 12 x 12 Floor Tile	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Beige, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 16.9%			
5 3	221021080-05 <b>Location:</b> Librarian's Office / Kitchenette - Brown 12 x 12 Floor Tile & Adhesive "Insufficient Mastic For Preparation"	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Gray/Beige, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 3.1%			

**PLM Bulk Asbestos Report**

21-131; Woodstock Library; Renovation Survey / Interior

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
6	221021080-06	No	NAD
3	Location: Librarian's Office / Kitchenette - Brown 12 x 12 Floor Tile & Adhesive "Insufficient Mastic For Preparation"		(by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Gray/Beige, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 3.2%			
7	221021080-07L1	No	NAD
4	Location: Librarian's Office - Off-White 12 x 12 Floor Tile & Adhesive / Tile		(by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Beige, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 2%, Non-fibrous 18.4%			
7	221021080-07L2	No	NAD
4	Location: Librarian's Office - Off-White 12 x 12 Floor Tile & Adhesive / Adhesive		(by NYS ELAP 198.6) by Valeriu Voicu on 02/05/21
<b>Analyst Description:</b> Beige/Tan, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 1%, Non-fibrous 18.6%			
8	221021080-08L1	No	NAD
4	Location: Librarian's Office - Off-White 12 x 12 Floor Tile & Adhesive / Tile		(by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Beige, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass Trace, Non-fibrous 9.1%			
8	221021080-08L2	No	NAD
4	Location: Librarian's Office - Off-White 12 x 12 Floor Tile & Adhesive / Adhesive		(by NYS ELAP 198.6) by Valeriu Voicu on 02/05/21
<b>Analyst Description:</b> Beige/Tan, Heterogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 2%, Non-fibrous 44.7%			
9	221021080-09	No	NAD
5	Location: Public Bathroom / Foyer - Beige 12 x 12 Floor Tile		(by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Tan, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 20%			

**PLM Bulk Asbestos Report**

21-131; Woodstock Library; Renovation Survey / Interior

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
10 5	221021080-10 Location: Public Bathroom / Foyer - Beige 12 x 12 Floor Tile	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Tan, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 3.7%			
11 6	221021080-11 Location: 2nd Fl. / Throughout - Floor Covering Adhesive	Yes	12.9% (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> White/Beige, Heterogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> Chrysotile 12.9 % <b>Other Material:</b> Non-fibrous 19.3%			
12 6	221021080-12 Location: 2nd Fl. / Throughout - Floor Covering Adhesive		NA/PS
<b>Analyst Description:</b> Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b>			
13 7	221021080-13 Location: 2nd Fl. / Throughout - Speckled Floor Covering	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Off-White/Brown, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 23.1%			
14 7	221021080-14 Location: 2nd Fl. / Throughout - Speckled Floor Covering	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Off-White/Brown, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 24.6%			
15 8	221021080-15 Location: Janitor's Closet - Pink 12 x 12 Floor Tile	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Pink, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 10.5%			

**PLM Bulk Asbestos Report**

21-131; Woodstock Library; Renovation Survey / Interior

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
16 8	221021080-16 Location: Janitor's Closet - Pink 12 x 12 Floor Tile	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Pink, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 9.3%			
17 9	221021080-17 Location: Art Room - Textured Ceiling Plaster	Yes	7.5% (by NYS ELAP 198.1) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> White, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> Chrysotile 7.5 % <b>Other Material:</b> Non-fibrous 92.5%			
18 9	221021080-18 Location: Art Room - Textured Ceiling Plaster		NA/PS
<b>Analyst Description:</b> Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b>			
19 9	221021080-19 Location: Children's Library - Textured Ceiling Plaster		NA/PS
<b>Analyst Description:</b> Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b>			
20 9	221021080-20 Location: Children's Library - Textured Ceiling Plaster		NA/PS
<b>Analyst Description:</b> Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b>			
21 9	221021080-21 Location: West Addition - Textured Ceiling Plaster		NA/PS
<b>Analyst Description:</b> Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b>			



Client Name: Spectrum Environmental Associates, Inc.

**PLM Bulk Asbestos Report**

21-131; Woodstock Library; Renovation Survey / Interior

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
22 10	221021080-22 Location: Main Library Area / Ceiling - Glue 3 Dabs	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Dark Brown, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 48.3%			
23 10	221021080-23 Location: Main Library Area / Ceiling - Glue 3 Dabs	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Dark Brown, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 42.9%			
24 11	221021080-24 Location: Main Library Area / Ceiling - 12 x 12 Ceiling Tile	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> White/Tan, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 14.1%			
25 11	221021080-25 Location: Main Library Area / Ceiling - 12 x 12 Ceiling Tile	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> White/Tan, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 12.3%			
26 12	221021080-26 Location: Walls / Throughout - Plaster Skim Coat	No	NAD (by NYS ELAP 198.1) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> White/Yellow, Heterogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Cellulose Trace, Non-fibrous 100%			
27 12	221021080-27 Location: Walls / Throughout - Plaster Skim Coat	No	NAD (by NYS ELAP 198.1) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> White/Yellow, Heterogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Cellulose Trace, Non-fibrous 100%			

**PLM Bulk Asbestos Report**

21-131; Woodstock Library; Renovation Survey / Interior

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
28	221021080-28	No	NAD
12	Location: Walls / Throughout - Plaster Skim Coat		(by NYS ELAP 198.1) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> White/Yellow, Heterogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Cellulose Trace, Non-fibrous 100%			
29	221021080-29	No	NAD
12	Location: Ceilings / Throughout - Plaster Skim Coat		(by NYS ELAP 198.1) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> White, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 100%			
30	221021080-30	No	NAD
12	Location: Ceilings / Throughout - Plaster Skim Coat		(by NYS ELAP 198.1) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> White/Yellow, Heterogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Cellulose Trace, Non-fibrous 100%			
31	221021080-31	No	NAD
13	Location: Walls / Throughout - Plaster Base Coat		(by NYS ELAP 198.1) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Gray, Homogeneous, Non-Fibrous, Cementitious, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Cellulose Trace, Non-fibrous 100%			
32	221021080-32	No	NAD
13	Location: Walls / Throughout - Plaster Base Coat		(by NYS ELAP 198.1) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Gray, Homogeneous, Non-Fibrous, Cementitious, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Cellulose Trace, Non-fibrous 100%			
33	221021080-33	No	NAD
13	Location: Walls / Throughout - Plaster Base Coat		(by NYS ELAP 198.1) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Gray, Homogeneous, Non-Fibrous, Cementitious, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Cellulose Trace, Non-fibrous 100%			

**PLM Bulk Asbestos Report**

21-131; Woodstock Library; Renovation Survey / Interior

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
34 13	221021080-34 <b>Location:</b> Ceilings / Throughout - Plaster Base Coat	<b>No</b>	NAD (by NYS ELAP 198.1) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Gray, Homogeneous, Non-Fibrous, Cementitious, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Cellulose Trace, Non-fibrous 100%			
35 13	221021080-35 <b>Location:</b> Ceilings / Throughout - Plaster Base Coat	<b>No</b>	NAD (by NYS ELAP 198.1) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Gray, Homogeneous, Non-Fibrous, Cementitious, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Cellulose Trace, Non-fibrous 100%			
36 14	221021080-36 <b>Location:</b> Walls / Throughout - Joint Compound	<b>No</b>	NAD (by NYS ELAP 198.1) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> White, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Cellulose Trace, Non-fibrous 100%			
37 14	221021080-37 <b>Location:</b> Ceilings / Throughout - Joint Compound	<b>No</b>	NAD (by NYS ELAP 198.1) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> White, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Cellulose Trace, Non-fibrous 100%			
38 15	221021080-38 <b>Location:</b> Walls / Throughout - Sheetrock	<b>No</b>	NAD (by NYS ELAP 198.1) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Brown/White, Heterogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Cellulose 15%, Non-fibrous 85%			
39 15	221021080-39 <b>Location:</b> Ceilings / Throughout - Sheetrock	<b>No</b>	NAD (by NYS ELAP 198.1) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Brown/White, Heterogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Cellulose 10%, Non-fibrous 90%			

**PLM Bulk Asbestos Report**

21-131; Woodstock Library; Renovation Survey / Interior

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
40	221021080-40	No	NAD
16	Location: Vapor Barrier Bottom Layer Roof 1 Main Roof - Tar Paper		(by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 6%, Non-fibrous 2.8%			
41	221021080-41	No	NAD
16	Location: Vapor Barrier Bottom Layer Roof 1 Main Roof - Tar Paper		(by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 5%, Non-fibrous 1.3%			
42	221021080-42	No	NAD
17	Location: Mid Layer Roof 1 Main Roof - Shingle		(by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 3%, Non-fibrous 37.9%			
43	221021080-43	No	NAD
17	Location: Mid Layer Roof 1 Main Roof - Shingle		(by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 3%, Non-fibrous 36.6%			
44	221021080-44	No	NAD
18	Location: Top Layer Roof 1 Main Roof - Shingle		(by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Gray/Black, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 3%, Non-fibrous 36.9%			
45	221021080-45	No	NAD
18	Location: Top Layer Roof 1 Main Roof - Shingle		(by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Gray/Black, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 3%, Non-fibrous 26.3%			



**PLM Bulk Asbestos Report**

21-131; Woodstock Library; Renovation Survey / Interior

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
46 19	221021080-46 Location: Flat Roof Off Roof 1 Main Roof - Silver Coating	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Silver, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 24.6%			
47 19	221021080-47 Location: Flat Roof Off Roof 1 Main Roof - Silver Coating	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Silver/Black, Heterogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 24.1%			
48 20	221021080-48 Location: Vapor Barrier Bottom Layer Roof 2 -Tar Paper	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 2%, Non-fibrous 5.8%			
49 20	221021080-49 Location: Vapor Barrier Bottom Layer Roof 2 -Tar Paper	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 10%, Non-fibrous 1.8%			
50 21	221021080-50 Location: Top Layer Roof 2 -Shingle	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Gray/Black, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 2%, Non-fibrous 37.7%			
51 21	221021080-51 Location: Top Layer Roof 2 -Shingle	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Gray/Black, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 2%, Non-fibrous 36.6%			

**PLM Bulk Asbestos Report**

21-131; Woodstock Library; Renovation Survey / Interior

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
52	221021080-52	No	NAD
22	Location: Vapor Barrier Bottom Layer Roof 3 - Tar Paper		(by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 1.7%			
53	221021080-53		NA
22	Location: Vapor Barrier Bottom Layer Roof 3 - Tar Paper "Sample Not Submitted"		
<b>Analyst Description:</b> Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> <b>Comment:</b> Empty Sample Bag Submitted.			
54	221021080-54	No	NAD
23	Location: Mid Layer Roof 3 - Shingle		(by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black/Gray, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 3%, Non-fibrous 24.2%			
55	221021080-55	No	NAD
23	Location: Mid Layer Roof 3 - Shingle		(by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black/Gray, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 2%, Non-fibrous 30.9%			
56	221021080-56	No	NAD
24	Location: Top Layer Roof 3 - Shingle		(by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black/Gray, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 2%, Non-fibrous 41.1%			

**PLM Bulk Asbestos Report**

21-131; Woodstock Library; Renovation Survey / Interior

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
57 24	221021080-57 Location: Top Layer Roof 3 - Shingle	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black/Gray, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 2%, Non-fibrous 41.6%			
58 25	221021080-58 Location: Vapor Barrier Bottom Layer Roof 4 - Tar Paper	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 4%, Non-fibrous 8.3%			
59 25	221021080-59 Location: Vapor Barrier Bottom Layer Roof 4 - Tar Paper	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 5%, Non-fibrous 35.4%			
60 26	221021080-60 Location: Top Layer Roof 4 - Shingle	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 5%, Non-fibrous 15.6%			
61 26	221021080-61 Location: Top Layer Roof 4 - Shingle	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 7%, Non-fibrous 15.4%			
62 27	221021080-62 Location: Vapor Barrier Bottom Layer Roof 5 - Tar Paper	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 21.6%			

**PLM Bulk Asbestos Report**

21-131; Woodstock Library; Renovation Survey / Interior

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
63 27	221021080-63 <b>Location:</b> Vapor Barrier Bottom Layer Roof 5 - Tar Paper	<b>No</b>	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 26.4%			
64 28	221021080-64 <b>Location:</b> Top Layer Roof 5 - Shingle	<b>No</b>	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Gray/Black, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 44.6%			
65 28	221021080-65 <b>Location:</b> Top Layer Roof 5 - Shingle	<b>No</b>	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Gray/Black, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 44.8%			
66 29	221021080-66 <b>Location:</b> Vapor Barrier Bottom Layer Roof 6 -Tar Paper "Sample Not Submitted"		NA
<b>Analyst Description:</b> Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> <b>Comment:</b> Empty Sample Bag Submitted.			
67 29	221021080-67 <b>Location:</b> Vapor Barrier Bottom Layer Roof 6 -Tar Paper	<b>No</b>	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black, Homogeneous, Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Fibrous glass 7%, Non-fibrous 2.8%			



**PLM Bulk Asbestos Report**

21-131; Woodstock Library; Renovation Survey / Interior

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
68 30	221021080-68 Location: Mid Layer Roof 5 - Shingle	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 29.6%			
69 30	221021080-69 Location: Mid Layer Roof 5 - Shingle	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black/Green, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 41.3%			
70 31	221021080-70 Location: Top Layer Roof 6 - Shingle	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 14.5%			
71 31	221021080-71 Location: Top Layer Roof 6 - Shingle	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 47%			
72 32	221021080-72 Location: Shed Roof Connecting Roof 4 & Roof 5 - Flashing	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 10.3%			
73 32	221021080-73 Location: Shed Roof Connecting Roof 4 & Roof 5 - Flashing	No	NAD (by NYS ELAP 198.6) by Valeriu Voicu on 02/04/21
<b>Analyst Description:</b> Black, Homogeneous, Non-Fibrous, Bulk Material <b>Asbestos Types:</b> <b>Other Material:</b> Non-fibrous 9%			

## PLM Bulk Asbestos Report


21-131; Woodstock Library; Renovation Survey / Interior

---

### Reporting Notes:

Analyzed by: Valeriu Voicu

Date: 2/4/2021



Reviewed by: Gabriella Morozov



\*NAD/NSD =no asbestos detected; NA =not analyzed; NA/PS=not analyzed/positive stop, (SOF-V) = Sprayed On Fireproofing containing Vermiculite; (SM-V) = Surfacing Material containing Vermiculite; PLM Bulk Asbestos Analysis using Olympus, Model BH-2 Pol Scope, Microscope, Serial #: 229915, by Appd E to Subpt E, 40 CFR 763 (NVLAP 200546-0), ELAP PLM Method 198.1 for NY friable samples, which includes the identification and quantitation of vermiculite or ELAP 198.6 for NOB samples or EPA 400 pt ct by EPA 600-M4-82-020 (NY ELAP Lab 11480); Note:PLM is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. NAD or Trace results by PLM are inconclusive, TEM is currently the only method that can be used to determine if this material can be considered or treated as non asbestos-containing in NY State (also see EPA Advisory for floor tile, FR 59,146,38970,8/1/94) National Institute of Standards and Technology Accreditation requirements mandate that this report must not be reproduced except in full without the approval of the lab.This PLM report relates ONLY to the items tested. AIHA-LAP, LLC Lab ID 102843, RI Cert AAL-094, CT Cert PH-0186, Mass Cert AA000054, NJ Lab ID #NY031.

\_\_\_\_\_END OF REPORT\_\_\_\_\_