

30105 Beverly Road Romulus, MI 48174

Ph: 734-629-8161; Fax: 734-629-8431

## Certfcate of Analysis: Lead In Dust Wipes by Modifed ASTM 1644-17\* and EPA Method 7000B

Client: Flatley Read LLC

12 Spring Street Suite 102

Schuylerville, NY 12871

Attn: Michelle DeGarmo

Email: flatleyreadllc@gmail.com

**Phone**: 518-577-5681 **Client Project**: W0

Project Location :

WOOD RA EA

5 LIBRARY LANE WOODSTOCK NY 12498

Fax:

AAT Project :

637573

Sampling Date :

02/09/2021

Date Received :

02/12/2021

Date Analyzed : Date Reported : 02/15/2021

2/15/2021 6:23:46PM

Lab Sample ID	Client Code	Sample Description	Length (inch)	Width (inch)	Area (Sq ft)	Total µg	Results Lead µg/ft2
6115064	1	FRONT ENTRY F	12	12	1.00	<5	<5.00
6115065	2	MAIN STACKS WS	2	18	0.25	<5	<20.00
6115066	3	STAFF RM F	12	12	1.00	<5	<5.00
6115067	4	CENTER STACKS F	12	12	1.00	<5	<5.00
6115068	5	REAR ENTRY F	12	12	1.00	<5	<5.00
6115069	6	BOTTOM OF STAIRS SW1 F	12	12	1.00	<5	<5.00
6115070	7	PROG A F	12	12	1.00	<5	<5.00
6115071	8	PROG A WS	2	18	0.25	<5	<20.00

Analyst Signature

lyse Belle

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, Analytical Reporting Limit is 5 ug/sample. For true values assume (2) significant figures. AAT internal SOP S207. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 10 ug/ft2 (Floors, Carpeted/Uncarpeted), 100 ug/ft2 (Window Sill/Stools), 400 ug/ft2 (Window Trough/Well/Ext Concrete Surfaces). EPA Lead Dust Clearance Limits: 40 ug/ft2 (Floors, Carpeted/Uncarpeted), 250 ug/ft2 (Window Sill/Stools), 400 ug/ft2 (Window Trough/Well/Ext Concrete Surfaces). HUD Grantee Regulatory Limits: 10 ug/ft2 (Interior Floors), 400 ug/ft2 (Window Sills), 100 ug/ft2 (Window Trough), New York City Regulatory Limits: 10 ug/ft2 (Floors), 50 ug/ft2 (Window Sills), 100 ug/ft2 (Window Sills), 100





30105 Beverly Road Romulus, MI 48174

Ph: 734-629-8161; Fax: 734-629-8431

To: Flatley Read LLC

12 Spring Street Suite 102

Schuylerville, NY 12871

Michelle DeGarmo

AAT Project : Date Reported : 637573

Client Project :

WOOD RA EA

2/15/2021 6:23:46PM

Email: flatleyreadllc@gmail.com

Attn:

Phone: 518-577-5681

Project Location: 5 LIBRARY LANE WOODSTOCK NY 12498

Sample	Client Code	Analysis Requested	Completed	Analyst	
6115064	1	Dust Wipe	02/15/2021	Elyse Bidle	
6115065	2	Dust Wipe	02/15/2021	Elyse Bidle	
6115066	3	Dust Wipe	02/15/2021	Elyse Bidle	
6115067	4	Dust Wipe	02/15/2021	Elyse Bidle	
6115068	5	Dust Wipe	02/15/2021	Elyse Bidle	
6115069	6	Dust Wipe	02/15/2021	Elyse Bidle	
6115070	7	Dust Wipe	02/15/2021	Elyse Bidle	
6115071	8	Dust Wipe	02/15/2021	Elyse Bidle	

Reviewed By

Quality Assurance Coordinator - Stephen Northcott

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.

AIHA LAP- Lab ID #100986, NY State DOH ELAP -Lab ID #11864, State of Ohio- Lab ID # 10042